

Plymouth Community School Corporation Emergency Generator Inspection

These areas are to be inspected and forms completed monthly. Any repairs or comments MUST be accompanied by a work order. It is the Head Custodians responsibility to retain original signed forms for record retention. All forms are subject to scheduled and random inspections.

School: _____

Inspection Date: _____

EMERGENCY GENERATOR

Part	Satisfactory	Unsatisfactory	Comments
Battery System Charger			
Battery Terminals Clean and Tight			
Charger Rate			
Coolant Level			
Exhaust System			
Fuel Piping			
Fuses			
Hoses			
Jacket Water Heater			
Lube Oil Heater			
Overall Generator			
Prime Mover			
Tank Vents			
Water Pump			

Inspectors Signature: _____