PLYMOUTH COMMUNITY SCHOOL CORPORTATION

ACCESSIBILITY CHECKLIST

The following are to be checked to ensure they are in compliance with the accessibility needs of the disabled:

[]	All entrances and parking areas are properly delineated for access by the disabled
[]	Adequate parking areas are allocated for the disabled.
[]	Appropriate parking areas are provided for vans transporting the disabled.
[]	Parking for the disabled is located by the nearest accessible entrance.
[]	Parking area has an adjacent accessible aisle.
[]	No curbing interferes with access by the disabled.
[]	Entry doors have an opening force of no greater than five (5) pounds and are equipped with lever-style or U-shaped door handles.
[]	Accessible aisles are available throughout the facility.
[]	Water fountains and telephones are accessible to individuals with wheel-chairs.
[]	Indoor ramps are equipped with sufficient nonskid material.
[]	Adequate lavatory facilities are available to the disabled with accessible door latches, sinks, soap and towel dispensers, handrails, toilets and no unexposed piping under sinks.
[]	Aisles with adequate tables and/or work stations in classrooms and laboratories are accessible to disabled.
[]	Libraries/media centers have racks, tables, carrels, services counters accessible to the disabled.
[]	Aisles, tables, serving areas, disposal areas, and vending areas in lunchrooms are accessible to the disabled.
[]	Aisles in auditoriums are equipped with nonskid material.
[]	A visual alarm system is operational for the hearing impaired.